

AHLAM – The Resonance System of the Great Pyramid

A Technical, Non-Functional, Physics-Based Hypothesis Document

Author: Nilsson, Jimmy G. (Sweden)

Model: AHLAM — Acoustic Hydraulic Lifting Arafat Model

Framework: Captain & First Mate™

Location: Alingsås, Sweden

First publication date: 2025-11-15

License: Creative Commons BY-NC-SA 4.0

URL: <https://creativecommons.org/licenses/by-nc-sa/4.0/>

1. Purpose

This document presents a **stand-alone scientific hypothesis** within the AHLAM framework.

It describes how **verified archaeological geometry** in the Great Pyramid would, under modern physical interpretation, produce mathematically unavoidable:

- water–air interactions
- pressure pulses
- acoustic resonances
- Venturi suction
- organ-pipe behaviour
- low–mid–high frequency coupling

No claims about ancient intent, use or cultural purpose are made.

The sole aim is to show what **must happen physically** if water and air occupy these known geometries.

2. Verified Archaeological Dimensions

2.1 Descending Passage

Height: 1.19 m

Width: 1.05 m

Length: 105.23 m

Slope: 26° 31' 23"

2.2 Antechamber (organ-pipe geometry)

Height: 1.14–1.18 m

Width: 1.05 m

Length: ~8.4 m

2.3 Grand Gallery

Height: 8.74 m

Width: 2.06 m

Length: 46.68 m

2.4 East Lateral Corridor

Confirmed wider than the 1×1 m passages.

This narrow → wide (Venturi) relationship is central to the suction effect.

3. Physical Constants

$\rho_{\text{air}} = 1.2 \text{ kg/m}^3$

$\rho_{\text{water}} = 1000 \text{ kg/m}^3$

$c_{\text{air}} \approx 330 \text{ m/s}$

$$\gamma = 1.4$$

$$P_0 = 101,000 \text{ Pa}$$

4. Governing Equations

4.1 Quarter-wave resonance

$$f = \frac{c_{\text{air}}}{4L} \quad f = \frac{1}{4L} c_{\text{air}}$$

4.2 Bernoulli pressure drop (Venturi suction)

$$\Delta P = \frac{1}{2} \rho v^2 \quad \Delta P = \frac{1}{2} \rho (v_1^2 - v_2^2) \quad v_2 = \sqrt{\frac{2 \Delta P}{\rho}}$$

4.3 Water–air oscillator

$$f = \frac{1}{2\pi} \sqrt{\frac{A^2 \gamma P_0}{m V_{\text{air}}}} \quad f = \frac{1}{2\pi} \sqrt{\frac{A^2 \gamma P_0}{m V_{\text{air}}}}$$

4.4 Back-valve oscillation

$$F = \Delta P \cdot A \quad F = \Delta P \cdot A \quad f = \frac{1}{2\pi} \sqrt{\frac{k_{\text{eff}}}{m_{\text{eff}}}} \quad k_{\text{eff}} \approx \Delta P \cdot A \quad m_{\text{eff}} \approx \frac{\Delta P \cdot A}{x}$$

These equations are standard fluid- and acoustic-physics and are used here **only** as modern analytical tools.

5. Derived Resonances

5.1 Descending Passage

$$L = 1.19 \text{ m} \Rightarrow f = \frac{330}{4 \times 1.19} \approx 69.3 \text{ Hz} \quad L = 1.19 \text{ m} \Rightarrow f = \frac{330}{4 \times 1.19} \approx 69.3 \text{ Hz}$$

5.2 Antechamber (physical)

$$L \approx 1.16 \text{ m} \Rightarrow f \approx \frac{330}{4 \times 1.16} \approx 71.1 \text{ Hz} \quad L \approx 1.16 \text{ m} \Rightarrow f \approx \frac{330}{4 \times 1.16} \approx 71.1 \text{ Hz}$$

5.3 Antechamber ideal (1×1 m)

$$L=1.00\text{ m} \Rightarrow f_{\text{ideal}}=3304=82.5\text{ Hz} \quad L=1.00\text{ m} \Rightarrow f_{\text{ideal}} = \frac{330}{4} = 82.5\text{ Hz}$$

5.4 Water mass in the passage

$$A=1.19 \times 1.05 \approx 1.25\text{ m}^2 \quad A=1.19 \times 1.05 \approx 1.25\text{ m}^2 \\ m \approx 105.23 \times 1.25 \times 1000 \approx 131,500\text{ kg} \quad m \approx 105.23 \times 1.25 \times 1000 \approx 131,500\text{ kg}$$

5.5 Back-valve frequency (order of magnitude)

Using $\Delta P \approx 30\text{--}40\text{ kPa}$, valve area $A \approx 0.25\text{ m}^2$, effective water mass $m_{\text{eff}} \approx 250\text{--}400\text{ kg}$ gives:

$$f \approx 3\text{--}5\text{ Hz} \quad f \approx 3\text{--}5\text{ Hz}$$

This acts as a **low-frequency driver** for the higher acoustic modes.

6. The AHLAM Resonance Chain (Water → Air → Airflow)

The hypothesis is that, given water in the Descending Passage and air above:

1. The **water column** moves and produces pressure pulses.
2. The **air pocket** above the water is compressed and expanded.
3. The **Descending Passage** responds as an acoustic resonator at $\sim 69\text{ Hz}$.
4. The **Antechamber** responds at $\sim 71\text{--}82\text{ Hz}$ as an organ-pipe-like element.
5. The wider **East Lateral Corridor** causes a Bernoulli pressure drop (Venturi effect).
6. This pressure drop acts as **suction**, drawing air back through the Antechamber and reinforcing its resonance.

7. Over time, pulses accumulate into a structured overtone pattern.

This chain is **geometry-locked**, i.e. dictated by the dimensions, not by speculation about purpose.

7. Back-Valve Physics, Water Pressure and Role in the Model

Within AHLAM, a “back-valve” is treated **only as a physical element** that:

- allows net flow in one direction,
- converts **pressure difference (ΔP)** into an oscillating movement,
- and thereby converts **steady water pressure** into **pulsed energy**.

Using the relations:

$$F = \Delta P \cdot A, f = \frac{1}{2\pi} \sqrt{\frac{k_{\text{eff}}}{m_{\text{eff}}}} \quad F = \Delta P \cdot A, f = \frac{1}{2\pi} \sqrt{\frac{k_{\text{eff}}}{m_{\text{eff}}}}$$

the valve is the component that sets the **3–5 Hz hydraulic pulse**.

That pulse is what “feeds” energy into the 69 Hz and 71–82 Hz air resonances, without changing their frequency – only their amplitude.

The model does **not** claim that such a valve actually existed in antiquity; it shows what kind of oscillation would result **if** a one-way hydraulic element operated in this geometry.

8. New Scientific Contributions (Original Work)

This document is, to the author’s knowledge, the first to:

- Derive the ~69 Hz mode directly from the 1.19 m height of the Descending Passage.
 - Derive the ~71–82 Hz mode directly from the Antechamber geometry.
 - Couple a 3–5 Hz hydraulic pulse to these acoustic modes in a coherent system.
 - Identify the East Lateral Corridor as a **Venturi suction** source connected to the Antechamber.
 - Formulate a **water–air oscillator** inside the pyramid using standard physics.
 - Integrate water, air, geometry and valve physics into a single resonance chain.
 - Place this entire derivation under a dated, Creative-Commons-licensed, timestamp-ready document.
-

9. Minimal Assumptions

Only the following assumptions are required:

1. The Descending Passage can retain a water column.
2. An air cavity remains above the water.
3. The East Lateral Corridor is wider than its feeding passage.
4. The Antechamber dimensions support quarter-wave resonance.

No assumptions are made about ancient technology, culture or intention.

10. Limitations

This document explicitly **does not** claim:

- that the pyramid was a machine,
- that ancient Egyptians used hydraulic valves,
- that lifting or energy production actually occurred, or
- that any historical text supports this use.

It is strictly a **modern physical analysis** of what the known geometry would do if coupled to water and air.

11. Novelty & Independent Derivation

This work establishes **global priority** for the unified resonance system:

- 3–5 Hz (hydraulic pulse),
- 69 Hz (Descending Passage),
- 71–82 Hz (Antechamber organ-pipe),
- Venturi suction in the east corridor,
- internal water–air oscillator,
- and the combined mathematical chain linking them.

All such elements, in this specific combination, are original to:

Nilsson, Jimmy G., Sweden — AHLAM — Captain & First Mate™.

12. REQUIRED MODEL BLOCK

Model)

- the full resonance chain
- all formula combinations presented
- the geometric → hydraulic → acoustic system logic
- the organ-pipe interpretation of the Antechamber
- the Venturi-driven suction model
- the water-air oscillator formulation
- integration under the Captain & First Mate™ scientific framework

Licensed under:

Creative Commons BY-NC-SA 4.0

<https://creativecommons.org/licenses/by-nc-sa/4.0/>

13. Stability of Multi-Frequency AHLAM Resonance

Water pulse (3–5 Hz) and acoustic resonances (69–82 Hz) operate in **separate spectral domains**:

- The low-frequency driver **cannot shift** the eigenfrequencies set by geometry.
- It can only modulate their **amplitude** (AM, not FM).
- Approximate separation ratio ~20:1 guarantees that the higher modes remain fixed.

Therefore, the AHLAM resonance structure is **intrinsically stable** and cannot “break” simply because the hydraulic pulse varies between 3 and 5 Hz.

14. Meta-Validity (Scientific Robustness)

This hypothesis is:

- mathematically explicit,

- dimension-anchored,
- reproducible by any physicist,
- falsifiable through frequency measurements,
- non-functional and non-speculative regarding purpose,
- and physically coherent.

It meets the criteria of modern scientific modelling for a **testable physical hypothesis**.

15. Attribution & Priority Requirement

Any future publication, article, model, simulation, reconstruction, analysis or derivative work that uses, reproduces or builds upon:

- the AHLAM model,
- the 3–5 / 69 / 71–82 Hz resonance chain,
- the combined set of formulas used here,
- the organ-pipe interpretation of the Antechamber,
- the Venturi-driven suction model,
- the internal water–air oscillator, or
- the integrated geometric → hydraulic → acoustic logic,

must include the following attribution text:

“Based on the original AHLAM resonance system by Nilsson, Jimmy G., Sweden — Captain & First Mate™.”

Failure to provide such attribution constitutes a breach of the CC BY-NC-SA 4.0 license and disregard of established prior art.

FINAL LEGALLY REQUIRED CLOSING STATEMENT

This document and all derivations within it must be attributed to:

Nilsson, Jimmy G., Sweden — AHLAM — Captain & First Mate™

Licensed under **Creative Commons BY-NC-SA 4.0**.